

# ADITYA FIRE SERVICES

SALES & SERVICES OF FIRE FIGHTING EQUIPMENTS

Contact No:-9689817057,7710081808

Email Id:-adityafireservices1@gmail.com

Aditadivade4646@gmail.com

AFS/2023/697799

DATE-02/07/2023

## TEST CERTIFICATE

THIS IS TO CERTIFY THAT THE FOLLOWING FIRE EXTINGUISHERS HAVE BEEN TESTED BY US. AS PER RELEVANT IS SPECIFICATION AND SUPPLIED TO

M/S.—:SUNSHINE ENGLISH MEDIUM SCHOOL KHATAV. IS HYDRAULICALLY TESTED AS PER THE FOLLOWING DETAIL ....

Sr. No	Type Of Ext.	Qty	Test Pressure	IS.NO	Date Of issue	Expire Date	Result
1.	ABC TYPE FIRE EXTINGUISHER 6 KG.	07	30KGF/CM2	13849	02/07/2023	01/07/2024	OK

TOTAL NO. OF EXTINGUISHER CERTIFY TESTED - 07 Nos.

FURTHER, WE CERTIFY THAT THE ABOVE MATERIAL ARE MADE OF BEST QUALITY IN WORKMANSHIP FREE FROM ALL DEFECTS IN MATERIAL AND WORKMANSHIP, IF ANY INCONSISTENCY IN THE PERFORMANCES OF THE MATERIAL IN THE EVENT WE UNDERTAKE FREE REPAIRS OR REPLACEMENT DURING THE WARRANTEE PERIOD.

  
FOR, ADITYA FIRE SERVICES



Off : Plot No53, Near Bus Stop, At. Indavali, Post. Karandi, Taluka. Jaoli, District. Satara,  
Branch-Satara ,Shirwal ,Pune ,Mumbai, Kolhapur.